



Product Service

# CERTIFICATE

No. Z2 101162 0003 Rev. 00

**Holder of Certificate:** **Betop(EU) Tech GmbH**  
Rödingsmarkt 20  
20459 Hamburg  
GERMANY

**Certification Mark:**



**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 701262010601-00

**Valid until:** 2025-07-16

**Date,** 2020-08-11

( Zhulin Zhang )



# CERTIFICATE

No. Z2 101162 0003 Rev. 00

**Model(s):**

SRxxx-72M, xxx=360-395 in step of 5,  
 SRxxx-60M, xxx=300-330 in step of 5,  
 SRxxx-144M, xxx=370-400 in step of 5,  
 SRxxx-120M, xxx=310-335 in step of 5,  
 SRxxx-144MH, xxx=410-450 in step of 5,  
 SRxxx-120MH, xxx=340-375 in step of 5  
 xxx is standing for rated output power at STC

**Parameters:**

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

**Tested according to:**

IEC 61215-1:2016  
 IEC 61215-1-1:2016  
 IEC 61215-2:2016  
 IEC 61730-1:2016  
 IEC 61730-2:2016  
 EN 61215-1:2016  
 EN 61215-1-1:2016  
 EN 61215-2:2017  
 EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06

**Production Facility(ies):**

104990