

TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

CERTIFICATE

No. Z2 101162 0002 Rev. 00

Holder of Certificate: Betop(EU) Tech GmbH
 Rödingsmarkt 20
 20459 Hamburg
 GERMANY

Certification Mark:



Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
 Mono-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 701261807701-00

Valid until: 2023-04-01

Date, 2018-08-13 (Zhulin Zhang)



Product Service

CERTIFICATE

No. Z2 101162 0002 Rev. 00

Model(s): SR330-72M, SR335-72M, SR340-72M,
SR345-72M, SR350-72M, SR355-72M,
SR360-72M, SR275-60M, SR280-60M,
SR285-60M, SR290-60M, SR295-60M,
SR300-60M, SR250-54M, SR255-54M,
SR260-54M, SR265-54M, SR270-54M,
SR220-48M, SR225-48M, SR230-48M,
SR235-48M, SR240-48M.

Parameters:

Rated Output Power
at STC:

at STC: 330 W, 335 W, 340 W,
345 W, 350 W, 355 W,
360 W, 275 W, 280 W,
285 W, 290 W, 295 W,
300 W, 250 W, 255 W,
260 W, 265 W, 270 W,
220 W, 225 W, 230 W,
235 W, 240 W,

Application Class:

Class A

Max. System Voltage:

1500V DC

Test laboratory:

Yangzhou Opto-Electrical
Products Testing Institute.
No. 10 West Kaifa Road, Yangzhou
225009, Jiangsu, P.R.China.

Safety Class:

Class II

Construction:

Framed, with Junction box,
cable and connector.

Fire Safety Class:

Class C according to UL790

**Tested
according to:**

IEC 61215-1(ed.1)
IEC 61215-1-1(ed.1)
IEC 61215-2(ed.1)
IEC 61730-1(ed.2)
IEC 61730-2(ed.2)

**Production
Facility(ies):**

003600